

875—91.20 (89) CSD-1 Report.

91.20(1) The installer shall complete a Manufacturer's/Installing Contractor's Report for ASME CSD-1 (CSD-1 Report) for each object except for the following:

- a.* An object within the scope of 875—Chapter 95;
- b.* An object within the scope of 875—Chapter 96; or
- c.* A hot water supply boiler covered by ASME Section IV, Part HLW.
- d.* A boiler with a fuel input rating greater than or equal to 12,500,000 Btu per hour, falling within the scope of NFPA 85, Boiler and Combustion Systems Hazards Code.

91.20(2) The owner shall make the CSD-1 Report available for inspection.

[ARC 8283B, IAB 11/18/09, effective 1/1/10; ARC 9232B, IAB 11/17/10, effective 12/22/10]